

CurrentStatus	ID	facilityName	comments_Second	county	POC_Name	contact_.
Not Operating	14218001	ARCHDIOCESE OF GALVESTON HOUSTON - CIRCLE LAKE RETREAT CENTER WWTP	4. No power 10. no power, not currently collecting 13. On generator within one day hopefully Phone number 281-356-6764 not functional possibly due to storm.	Montgomery	Gloria Bustillo	281-900-7244
Not Operating	13563001	BEACH ROAD MUD - BEACH ROAD MUD WWTP	Tornado hit, the clarifier was hit by debris, draining system and trucking wastewater to Bay City, WWTP. The collection system is a vacuum system, the was damage, They are working on fixing the system	Matagorda	Emil Krejci	979-429-7081
Not Operating	14578001	BLOOMINGTON ISD - BLOOMINGTON JUNIOR HIGH AND HIGH SCHOOL WWTP	Misty Bansfield states the system has been out of power since the storm. Crews currently onsite working to restore power. Facility is waiting on inspectors for a full evaluation of the WWTP and collection system. Ms. Bansfield was given the TCEQ Region 14	Victoria	Misty Bansfield	361-649-6871
Not Operating	14177001	CANEY CREEK MUD - CANEY CREEK MUD OF MATAGORDA COUNTY	facility hit by tornado, debries landed on treatment units and caused damages to plant on generator	Matagorda	Doanld Fox	979-429-1027
Not Operating	11713001	CEDAR BAYOU PARK UTILITY DISTRICT - CEDAR BAYOU PARK WWTP	both lift station and facility are both currently under water and cannot be reached. permittee is concerned that the facility may not be operational when the water recedes	Harris	Jerald Landin	713-818-3602
Not Operating	13172002	CINCO MUD 1 - CINCO RANCH SOUTH WWTP	Waiting on a status update on WWTP. Alot of information was unknown.	Fort Bend	James Wolfe	281-740-6540
Not Operating	14581001	CITY OF BRAZORIA - CITY OF BRAZORIA WWTP	The whole treatment system is being bypassed because it is completely under water. The lift station to the plant is above water and accessible by boat, but the river has not crested.	Brazoria	David Jordan	979-798-2489
Not Operating	10008002	CITY OF CONROE - SOUTHWEST REGIONAL WWTP	plant located 5 miles form lake conroe record release from lake facility completely under water	Montgomery		936-521-5114
Not Operating	10495146	CITY OF HOUSTON - KINGWOOD CENTRAL WWTP	Q5. No power at plant, lift stations have no power. Transformers, elec. panels, and switch gear needs repair. The plant has major electrical issues. Plant has a bypass pump on the way to set up at the lift station. Generatoe and bypass pumps not working.	Harris	Johnathan Dawson	281-830-4015
Not Operating	10495151	CITY OF HOUSTON - WILLOW RUN WWTP	Plant decommissioned. This plant has been shut down and is not in operation.	Harris	Walid Samarneh, PE	832-395-5771
Not Operating	10108001	CITY OF LIBERTY - CITY OF LIBERTY MAIN WWTP	#4 under 10 ft of water Really unable to perform an assessment due to the majority of plant being under 10 ft of water	Liberty	Mark Reed	936-661-3424

Not Operating	10626001	CITY OF ORANGE - JACKSON STREET WWTP	9- The operational status of the collection system is unknown due to an electrical issue at the plant.	Orange	Timmy Campbell	409-238-9103
Not Operating	15294001	CITY OF PATTON VILLAGE - PATTON VILLAGE WWTP	9. All 5 lift stations flooded and submerged (now 3/5) WWTP has been shut down. Entire collections system including lift stations are under water.	Montgomery	Ryan Bobo	832-318-5348
Not Operating	10312001	CITY OF WEST COLUMBIA - CITY OF WEST COLUMBIA WWTP	WWTP is no longer accessible.	Brazoria	Terry Elliot	979-481-3027
Not Operating	14404001	CORIX UTILITIES TEXAS INC - MATAGORDA BAY NATURE PARK AND PRESERVE WWTP	-no structural damage, just power outage -Power expected to be and fully operational as soon as tomorrow, 8/31/2017	Matagorda	Gloria Broussard	512-306-4001
Not Operating	11844001	FOREST GLEN INC - FOREST GLEN WWTF	WWTP was shut off before it flooded. A digester is damaged and has leaks. Three tanks leaked out during the storm event. Currently everything is being contained and no spills are occurring. Lost approximately 18000 gallons of activated sludge (Mostly liqui	Walker	Justin Perrit	936-295-7641
Not Operating	13245001	GRAND LAKES MUD 4 - GRAND LAKES REGIONAL WWTP	System is innaccessible. System is underwater.	Fort Bend	Susan Young	281-258-1212
Not Operating	11061001	GREENWOOD UTILITY DISTRICT - GREENWOOD UTILITY DISTRICT WWTP	Flooded generator has to be dried out before use. 2 offsite lifts are operable. The subscriber district parkway has seven lift stations that we do not have complete status updates on. Collection status NOCNSSO. Overflows system is underwater.	Harris	Susan Young	281-258-1212
Not Operating	10528001	HARRIS COUNTY FWSD 52 - HARRIS COUNTY FWSD 52 WWTF	3.Water is 7 feet deep, flooded generator. Power to meter only. Fuses being replaced today 5. Chlorine contact basin needs repair/replacement. Aeration basins nd clarifier OK. 6. WWTP should be fully operational by Saturday or Sunday 7. WWTP not operation	Harris	Phillip Dautrich	832-473-6578
Not Operating	11523001	HARRIS COUNTY MUD 102 - HARRIS COUNTY MUD 102 WWTP	Disinfection. Collection is partial. Parts are underwater.	Harris	Susan Young	281-258-1212
Not Operating	10104001	HARRIS COUNTY WCID 1 - HARRIS COUNTY WCID 1 WWTP	2. Unknown - facility is still partially flooded 5. Power + Units to feed the chlorine + SO2 compromised/Cannot Access basins until flood waters recede further 8. Clear Lake lift station needs new motors, electrician is on-site now 11. Reported to Region	Harris	Mark Taylor	281-426-2115
Not Operating	12128001	HORSEPEN BAYOU MUD - WILLIAM H PORTER WWTP	Yes - all four blowers continued to run pumping creek water thru the plant. Once we arrived we shut off two of the pumps.Parts of the system is underwater however all lift stations are okay,	Harris	Susan Young	281-258-1212

Not Operating	11518001	HUFFMAN ISD - WILLIE J HARGRAVE HIGH SCHOOL WWTP	5 ft of water in facility David Walker 8322501142	Harris	Doug Wade	832-465-8029
Not Operating	11290001	JACKRABBIT ROAD PUD - JACKRABBIT ROAD PUD WWTP	has more informtion on the plant	Harris	John Montgomery	281-217-1031
Not Operating	11084001	LAKE FOREST PLANT ADVISORY COUNCIL - LAKE FOREST REGIONAL WWTP	Flooded but the pl;ant can handle being flooded (made for it). Lift station may be down. Facility is 10 miles down creek.	Harris	Gregory Camp	281-902-0966
Not Operating	15089001	MONTGOMERY COUNTY MUD 139 - MONTGOMERY COUNTY MUD NO 139 WWTP	The WWTP is not operating. Have lost grid power from Entergy. They have called into Entergy to report outage. Disinfection is working. They have not yet checked on the generator. I asked Mr. Reno to call me back, but we should check on him in a day or	Montgomery	James Reno	832-381-8140
Not Operating	11386001	MONTGOMERY COUNTY MUD 16 - MONTGOMERY COUNTY MUD NO 16 WWTP	Lost power for waster treatment plant. The generator was damaged due to floods (powererd by diesel). Power has been out for 2 days. they are adding chlorine to the water to disinfect. 4 feet of water in the facility electircal is out. basins and collectio	Montgomery	Stephen Woodring	281-850-7001
Not Operating	14319001	ODA, MIKE - RIVERBEND RV PARK AND RESORT WWTP	5. RV park evacuated, WWTP off for 6 days 4. RV park has been evacuated 3. and 5. Anticipate for power to be back on in net few days, waiting for flooding to subside No damage aside from flooding has been assessed 8. collection system will be assessed	Fort Bend	Elena Oda	832-455-1612
Not Operating	13804001	TEXAS DEPARTMENT OF CRIMINAL JUSTICE - TERRELL WWTP	3. Generators are available. 4. plant is shut off due to current flooding and evacuation. 9. unknown Entire facility is shut down. Fllood water has to recede before knowing status	Brazoria	Tony Robinson	936-355-2829
Not Operating	14619001	TEXAS DEPARTMENT OF TRANSPORTATION - GUADALUPE COUNTY TXDOT IH-10 REST STATIONS	The WWTP is down due to power failure. Everything should work fine once power is restored.	Guadalupe	Ned Pyatt	512-952-1840
Not Operating	11141001	TRESCHWIG JOINT POWERS BOARD - TRESCHWIG CENTRAL WWTP	Plant is offline - flooded (unknown status) Lift station is damaged. Park is closed so no one has been affected.	Harris	Gregory Camp	281-902-0966
Not Operating	12088001	US ARMY CORPS OF ENGINEERS - ROCKY CREEK PARK WWTP		Washington	Randall McCartney	979-596-1624
System Destroyed	12936001	BOLIVAR UTILITY SERVICES LLC - CRYSTAL PALACE WWTP	Crystal Palace completely destroyed, no access 39 Million gallons of water is covering the system. No Power. They are flooded. They are next to an 8foot levee San Jacinto River. They are trying to get their hands on pumps. They evacuated the plant. They are still in need of pumps. they have pumps but	Galveston	Chris Makin	409-684-9941
System Destroyed	11329001	NEWPORT MUD - NEWPORT MUD WWTP		Harris	Cullen Francis	832-250-8367